

CM/GC QUESTION REQUEST FORM QR

PROJECT: NH-I-240-1(294), CM/GC CONTRACT No.:CMGC02

DATE:6/7/16

RFP Section ID	Question	Reserved for Agency Response
	What is the timeframe for the High Voltage transmission lines MLGW considering the summer peak when de-energizing is not possible?	June 1st to October 1st
	Is this 24 hours a day or would there be potential for night time de-energizing?	Any outage is subject to approval from TVA and contingent on the weather/temperatures at the time; consequently, a night time outage may possible and cannot be guaranteed.
	Above the western end of WB Poplar Avenue there is a 161kVA line. Based on survey it appears to be 36' +/- above the roadway. Do MLGW know the amount of clear distance a crane will be require to work below this energized line?	20'